



## DECLARATION OF CONFORMITY CE No. 06/2010

The undersigned hereby declares under his sole responsibility, that the product is in conformity with the technical specification as in point 4, if assembled in accordance with the Instruction Manual for Installation and Operation.

1. Manufacturer of the product: ***FIRMA WIŚNIOWSKI; 33-311 Wielogłowy 153***  
(full name and address of the manufacturer)

.....**POLAND**.....

2. Description of the product:  
***UNIPRO S power operated sectional door with OPTIMUM 600 electric drive unit***

(description, brand name, type, class)

3. Assignment and application of the product:  
***the door has been designed to be used as a vertical barrier for residential buildings***.....

(in accordance with the referenced document)

4. Technical specification:  
***EN 13241-1:2003 Industrial, commercial and garage doors and gates – Product standard - Part 1: Products without fire resistance or smoke control characteristics. Directives: 89/106/EEC, 98/37/EC, 73/23/EEC/, 89/336/EEC.***  
(number, title and date of issue of the Polish Standard, title and date of issue of technical approbation, name of the approving organization )

5. Declared technical specifications of the product:

Essential characteristic	Standards	Test results
Low voltage conformity	73/23/EEC	Pass
Electromagnetic conformity	89/336/EEC	Pass
Water tightness	EN 13241-1 p.4.4.2	Class 1
Release of dangerous substances	EN 13241-1 p.4.2.9	Not applicable
Resistance to wind load	EN 13241-1 p.4.4.3	Class 2
Thermal resistance	EN 13241-1 p.4.4.5	1,07 W/m <sup>2</sup> K
Air permeability	EN 13241-1 p.4.4.6	Class 4
Safe opening	EN 13241-1 p.4.2.8	Pass
Definition of geometry of glass components	EN 13241-1 p.4.2.5	Pass
Mechanical resistance and stability	EN 13241-1 p.4.2.3	Pass
Operating forces (for power operated doors)	EN 13241-1 p.4.3.3	Pass

6. Name and number of the authorized Certifying Organization or Testing Laboratory and certification number or number of the test report:  
***INSTITUTE OF BUILDING ENGINEERING; European Notified Body, number 1488***  
***Test report number NL-3144/A/LL-009/K/05***

KIEROWNIK  
biura konstrukcyjnego

*mgr inż. Dariusz Złocki*

.....  
(signature of authorized person)

Nowy Sącz 01.09.2010 r.  
(place and date of issue)